



- SPECIFICATIONS:**
1. THE SEPTIC TANK MUST BE EQUIPPED WITH AN EFFLUENT FILTER THAT HAS BEEN TESTED AND SHOWN TO PREVENT THE PASSAGE OF SOLIDS LARGER THAN 1/8 INCH.
 2. CAPACITY = 1,008 GALLONS
 3. FULL CAPACITY = 1,213 GALLONS
 4. GALLONS PER INCH = 20.55 (AVERAGE)
 5. WEIGHT = 8,280 POUNDS
 6. MAXIMUM OF 3 FEET OF COVER
 7. TANK TO MEET ASTM 1227C REQUIREMENTS
 8. TOP SEAM CONSTRUCTION
 9. JOINT SEALANT IS BUTYL RUBBER MASTIC TYPICAL OF CONSEAL CS-102.
 10. NOT DESIGNED FOR TRAFFIC AREAS
 11. ALL DIMENSIONS SHOW ARE PER ONSITE SEPTIC SOLUTIONS, LLC PRODUCTS 2011.

1,000 GALLON TOP SEAM PRECAST CONCRETE SEPTIC TANK

1/2" = 1'-0"



BUSINESS PARK AT CAMBRIDGE
 CAMBRIDGE, VT. 05444
 paul@onsitesepoticsolutions.biz
 TEL. 802-644-5500