



PLAN

SECTION

1,500 GALLON TOP SEAM PRECAST CONCRETE PUMP STATION

1/2" = 1'-0"

- NOTES:
1. FOR PUMP SPECIFICATIONS REFER TO PUMP DESIGN BRIEF.
 2. THE CONTRACTOR AND SUPPLIER SHALL COORDINATE POWER REQUIREMENTS PRIOR TO ORDERING OF THE PUMP STATION.
 3. PER ONSITE SEPTIC SOLUTIONS, LLC (SUPPLIER), THE TOP OF THIS TANK SHALL BE BURIED NO DEEPER THAN 3 FEET BELOW FINISHED GRADE. IF A DEEPER BURIAL DEPTH IS NEEDED SEE SUPPLIER FOR SIMILAR TANKS THAT CAN BE BURIED DEEPER THAN 3 FEET.
 4. REFER TO THE PUMP STATION DESIGN BRIEF OR CONSULT THE DESIGNER ON THE NEED FOR A WEEP HOLE OR NOT.

- SPECIFICATIONS:
1. TANK TO MEET ASTM 11227C REQUIREMENTS
 2. TOP SEAM CONSTRUCTION
 3. NOT DESIGNED FOR TRAFFIC AREAS
 4. ALL DIMENSIONS SHOWN ARE PER ONSITE SEPTIC SOLUTIONS, LLC PRODUCTS 2011.

3" SCH 40 PVC CARBON FILTER VENT
SCREW ON LID
EXTRA WIRE
JUNCTION BOX
24" DIAMETER ONSITE SEPTIC SOLUTIONS RISER, HEIGHT AS REQUIRED
PVC FLOAT SUPPORT
3/4" WEEP HOLE TO ALLOW FOR FORCEMAIN TO DRAIN BACK CONSULT WITH DESIGNER ON THE NEED OF THE WEEP HOLE



BUSINESS PARK AT CAMBRIDGE
CAMBRIDGE, VT. 05444
paul@onsitesepoticsolutions.biz
TEL. 802-644-5500