



**48" I.D. PUMP STATION**

1/2" = 1'-0"

- NOTES:**
1. PUMP SHALL BE CAPABLE OF XX GPM @ XX TDH.
  2. THE CONTRACTOR AND SUPPLIER SHALL COORDINATE POWER REQUIREMENTS PRIOR TO ORDERING OF THE PUMP STATION.
  3. IF REQUESTED THIS PUMP STATION CAN BE SETUP AS A DUPEX PUMP STATION.
  4. PER ONSITE SEPTIC SOLUTIONS, LLC (SUPPLIER), THE TOP OF THIS TANK SHALL BE BURIED NO DEEPER THAN 3 FEET BELOW FINISHED GRADE. IF A DEEPER BURIAL DEPTH IS NEEDED SEE SUPPLIER FOR SIMILAR TANKS THAT CAN BE BURIED DEEPER THAN 3 FEET.
  5. REFER TO THE PUMP STATION DESIGN BRIEF OR CONSULT THE DESIGNER ON THE NEED FOR A WEEP HOLE OR NOT.
- SPECIFICATIONS:**
1. TANK TO MEET ASTM C-478 REQUIREMENTS
  2. TOP SEAM CONSTRUCTION
  3. NOT DESIGNED FOR TRAFFIC AREAS
  4. ALL DIMENSIONS SHOW ARE PER ONSITE SEPTIC SOLUTIONS, LLC PRODUCTS 2011.



BUSINESS PARK AT CAMBRIDGE  
 CAMBRIDGE, VT. 05444  
 paul@onsitesepoticsolutions.biz  
 TEL. 802-644-5500